

HYDROTECH LABORATORY

Email : hydrotechlab@rediffmail.com, / hydrotechlaboratory@gmail.com Mobile : 9970213616 / 8806923476

DATE OF ISSUE: 14.03.2022

REPORT NUMBER : HTL/21-22/1445

CUSTOMER NAME : CM INTERNATIONAL SCHOOL: BALEWADI

SAMPLE IDENTIFICATION: PMC WATER

SAMPLE DETAILS

RECEIPT DATE	10.03.2022	TYPE	WATER
NO.	01	COLLECTED BY	HYDROTECH LABORATORY

DRINKING WATER ANALYSIS REPORT

SR. NO.	PARAMETERS	VALUE	IS 10500:2012 LIMITS	METHOD OF ANALYSIS
1.	pH	7.09	6.5-8.5	IS 3025 (part 11) :1983
2.	Turbidity(NTU)	Nil	1(Max.)	IS 3025 (part 10) :1984
3.	Total Alkalinity as CaCO ₃ (mg/Litre)	10.00	200(Max.)	IS 3025 (part 23) :1983
4.	Total Hardness as CaCO ₃ (mg/Litre)	10.00	200(Max.)	IS 3025 (part 21) :1983
5.	Chlorides as Cl (mg/Litre)	10.62	250(Max.)	IS 3025 (part 32) :1988
6.	Total Dissolved Solids(mg/Litre)	35.00	500(Max.)	IS 3025 (part 16) :1984
7.	Iron as Fe(mg/Litre)	Nil	0.3(Max.)	IS 3025 (part 53) :2003
8.	Sulphates as SO ₄ (mg/Litre)	Nil	200(Max.)	IS 3025 (part 24) :1986
9.	Nitrates as NO ₃ (mg/Litre)	Nil	45(Max.)	IS 3025 (part 34) :1988
10.	Fluoride as F(mg/Litre)	Nil	1(Max.)	IS 3025 (part 60) :2008
11.	Calcium as Ca(mg/Litre)	3.20	75(Max.)	IS 3025 (part 40) :1991
12.	Magnesium as Mg(mg/Litre)	0.48	30(Max.)	IS 3025 (part 46) :1994
13.	Coliform MPN(No. per 100 ml)	Nil	Nil	IS 1622:1981
14.	E.Coli (per 100 ml)	Absent	Absent	IS1622:1981

Please note that IS refers to Indian Standard, a specification published by Bureau of Indian Standards.

Note: Chemical and Microbial analysis reveals that above water sample is **POTABLE**.
(SUITABLE FOR DRINKING)

Subhanshu
FOR HYDROTECH LABORATORY

Subhanshu
CM International School
Balewadi

Note: This analysis report is extended as technical assistance only & Hydrotech Laboratory will not be involved in any legal dispute arising out of this report.

HYDROTECH LABORATORY

Office No.01, Mallikarjun Heights,
Left Bhusari Colony, P.O. - 401 004,
Near Chandani Chawl, Pune - 411 008
Contact No.9970213616 / 8806923476
Email id : hydrotechlaboratory@gmail.com
hydrotechlab@rediffmail.com

Iqbal Kaur
Principal

CM International School





Assistant Commissioner
Aundh - Baner Ward Office
Pune Municipal Corporation
Out Door No:- 9118
Date :- 9/3/2022

PERFORMA REGARDING HEALTH & SANITARY CONDITION
CERTIFICATE


No. 9118


Date : 09/03/2022


It is certified that an inspection team headed by Shri. Nitin Lokhande Shri. Jalindhar Chandgude, from Health Department, Aundh - Baner Ward Office, Pune Municipal Corporation Inspection the C M International School Sr. No. 4/2, 4/3 Dasara Chowk Balewadi on 09/03/2022 And found that the C M International School has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the School building and the campus as per the norms prescribed by the Central/ State/ U.T. Govt

The above valid for a period of 09/03/2022 to 08/03/2023

To,
C M International School
Sr. No. 4/2, 4/3 Dasara Chowk
Balewadi, Pune 411045


आरोग्य निरीक्षक
औंध-बाणेर क्षेत्रीय कार्यालय
पुणे महानगरपालिका


वरिष्ठ आरोग्य निरीक्षक
औंध-बाणेर क्षेत्रीय कार्यालय
पुणे महानगरपालिका


C M International School
Balewadi


Principal
C M International School